

NEDERLAND FIRE PROTECTION DISTRICT GATE PERMIT REQUIREMENTS

Plans and/or spec sheets are required on all permit submissions to Nederland Fire.
Permit applications must be submitted online and upon approval will be good for 180 days.

[SUBMIT PERMIT APPLICATION](#)

Nederland Fire Protection District requires a Knox rapid access solution to be installed on new gates constructed within the district.



You may either install a Knox gate key switch, or a Knox padlock.

Please visit [Gate Key Switches and Padlocks - Knox Rapid Access System \(knoxbox.com\)](http://knoxbox.com) and select Nederland Fire Protection District.



Gate & Key Switches



Knox Padlock